

Test Report

No. SDHL1604005752FB

Date: Apr.27, 2016

Page 1 of 3

RELIANCE PLUS LTD
UNIT E, 19/F E-TRADE PLAZA, 24 LEE CHUNG STREET, CHAI WAN, HONG KONG.

The following sample(s) was / were submitted and identified on behalf of the client as:

Sample Description : DPC CLEAR
 SGS Ref. No. : GZIN1604016250PC
 Product Specification : 0.40MMX54"
 Product Or Lot No. : 0102983
 Sample Receiving Date : Apr.20, 2016
 Test Performing Date : Apr.20, 2016 to Apr.27, 2016

Test Result Summary

No.	Test(s) Requested	Result(s)	Comments
1	NFPA 701 Test Method 2(flat) 2015 Edition: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films	PASS	/
For further details, please refer to the following page(s)			

Signed for and on behalf of
Shunde Branch
SGS-CSTC Co., Ltd.



Kevin Pan
Approved signatory



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd.
Shunde Branch, Shunde District, Guangdong Laboratory

1F, 1st Building European Industrial Park, No.1 Shunheran Road, Wusha Section, Daikang Town, Shunde, Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgs.com.cn
 中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Test Report

No. SDHL1604005752FB

Date: Apr.27, 2016

Page 2 of 3

Test Conducted:

NFPA 701 Test Method 2(flat) 2015 Edition: Standard Methods of Fire Tests for Flame Propagation of Textiles and Films

Sample Details

Name / Color:	Plastic / Transparent
Weight:	About 533 g/m ²
Products configuration	Single layer

Test Results:

Original State tested to Chapter 15 of NFPA 701-Method 2 for Flat

Specimen	Char Length (Inches)	After flame (Seconds)	Flaming Residue (Seconds)	Rating
1	6.7	0	0	Pass
2	7.2	0	0	Pass
3	6.4	0	0	Pass
4	7.3	0	0	Pass
5	7.0	0	0	Pass
6	7.5	0	0	Pass
7	6.5	0	0	Pass
8	7.9	0	0	Pass
9	6.8	0	0	Pass
10	6.4	0	0	Pass

Remark:

As per client request that the leaching specimens were not tested.

Requirements:

1. The time of individual specimen continues flaming was not more than 2 seconds after the test flame is removed from contact with the specimen.
2. The length of char of any single flat specimen does not exceed 435 mm (17.1in).
3. The time of portions or residues continues flaming was not more than 2 seconds.

Conclusion:

The submitted sample meets the requirements of NFPA 701 Test Method 2-2015 Edition.



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CTI Standards Technical Services Co., Ltd.
Shunde Branch / 顺德检测实验室

1F, 1st Building, European Industrial Park, No.1 Shunshen Road, Wusha Section, Daliang Town, Shunde Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgs.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号楼首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com

Photo Appendix:



End of Report



SGS-CTI Standards Technical Services Co., Ltd.
Shunde Branch, Shunde Customs Commodity Laboratory

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1/F, 1st Building, European Industrial Park, No. 1 Shunhemen Road, Wusha Section, Daikang Town, Shunde, Foshan, Guangdong, China 528333 t (86-757)22805888 f (86-757)22805858 www.sgsgroup.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙顺和南路1号欧洲工业园一号厂房首层 邮编: 528333 t (86-757)22805888 f (86-757)22805858 e sgs.china@sgs.com